



Het advies



	Huidige staat	Essentieel	LTV	Nieuwbouw	Passiefhuis
Totaal verbruik	116,55 kWh/m ²	66,61 kWh/m ²	66,22 kWh/m ²	61,37 kWh/m ²	54,19 kWh/m ²
Verwarming	67,63 kWh/m ²	32,56 kWh/m ²	16,62 kWh/m ²	8,14 kWh/m ²	2,72 kWh/m ²
Warm tapwater	1,78 kWh/m ²	1,78 kWh/m ²	1,78 kWh/m ²	1,79 kWh/m ²	1,80 kWh/m ²
Koeling	1,62 kWh/m ²	1,33 kWh/m ²	2,15 kWh/m ²	3,37 kWh/m ²	2,1 kWh/m ²
Elektriciteit (overig)	47,14 kWh/m ²	30,94 kWh/m ²	45,67 kWh/m ²	48,07 kWh/m ²	47,62 kWh/m ²



	Huidige staat	Nieuwbouw standaarden
Vloer [m ² K/W]	2,5	3,7
Gevel [m ² K/W]	2,5	4,7
Dak [m ² K/W]	2,5	6,3
Ramen [W/m ² K]	5,3	1,65
Qv;10 [dm ³ /s per m ²]	1,0	0,3
Installaties	Externe warmtelevering	LT WKO + WP Vloer verw.